

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection report emailed to Claudine Windsor on 03/06/2023.

At the time of the inspection no shower onsite was observed.

Email Address(es): cwinsor@dadeschools.net;
jaybolton@dadeschools.net;
mwertz@dadeschools.net;
ipalacio@dadeschools.net;
wcabrera@dadeschools.net

Violations Comments

Violation #6. Lighting Standards

Observed lights out of order in Boys bathrooms : 6-002G and -008G in building 6. Repair lights.

Observed lights out of order in classrooms F11 and F8 in . Repair lights.

Observed lights out of order in classrooms: POD C , POD D and 6-009C in building 6. Repair lights.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Violation #13. Handwashing Facilities

Observed handwashing sink is out of order in boys restroom in building 5. Repair handwashing sink.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Violation #18. Drinking Fountains

Observed two drinking fountains out of order: one by classroom 15 in building 5 and second one by classrom 8 in building 4. Replace drinking fountains.

CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.

Inspection Conducted By: Cesar Martinez (085423)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 3/6/2023

Inspector Signature:

CM

Client Signature:

Claudine Windsor